



Lacasa TRP Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005672	5/31/2020	5/31/2021	2	Cooler	In hallway adjacent to room 204	WF-05312020-005672	3/10/2021	FT-FY21-022021-005672-A	<1	FT-FY21-022021-005672-B	<1
WS- 005673	5/31/2020	5/31/2021	3	Cooler	In hallway adjacent to room 308	WF-05312020-005673	3/10/2021	FT-FY21-022021-005673-A	<1	FT-FY21-022021-005673-B	<1